

1. UH Campus (MOI, MUPC, TH, CCA, PCT, LC, and HSMB), Quarterdeck, and several other off-site properties utilize Johnson Control (JCI) Metasys®. All controllers and thermostats are provided by the Owner. Replace all pneumatic controls during renovation.
2. WH utilizes Siemens. There is no plan to change the WH BAS system to JCI at this time.
3. Occupancy Sensors shall not utilize ultrasonic technology as it interferes with other systems in use. Plan density of sensors accordingly.
4. For additional guidelines, see [UM Consultant Procedures and Design Guidelines](#), Division 23.

END OF SECTION